



**HEALTH AND FOOD SAFETY DIVISION**

550 Landa Street  
 New Braunfels, TX 78130  
 Office: 830-221-4070  
 Email: health@nbtexas.org  
[www.nbtexas.org](http://www.nbtexas.org)

**Public  
 Swimming Pools and  
 Spas**

<b>Facility Name:</b>		<b>Date:</b>	
<b>County:</b> COMAL / GUADALUPE		<b>Phone:</b>	
<b>Facility Address:</b>		<b>City:</b> NEW BRAUNFELS	
<b>Mailing Address:</b>		<b>State/Zip:</b>	
<b>Permit Number:</b>	<input type="checkbox"/> Indoor <input type="checkbox"/> Outdoor	<input type="checkbox"/> Class A <input type="checkbox"/> Spa	<input type="checkbox"/> Class B <input type="checkbox"/> Wade
<input type="checkbox"/> Class C <input type="checkbox"/> w/PIWF			
<b>Inspection Type:</b> <input type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Re-Inspection <input type="checkbox"/> Pre-Licensing <input type="checkbox"/> Other (specify):			

“X” indicates an alleged deficiency

“COS” indicates corrected on-site

**SWIMMING POOL OR WADE POOL**

1. Chlorine 1.0 to 8.0 ppm	
2. Bromine 3.0 to 10.0 ppm	
3. pH 7.0 to 7.8	
4. Cyanuric Acid: Max 100ppm	
5. Water clarity sufficient / no algae present	
6. DPD test kit in use is reliable and properly stored	
7. Deck & sidewall depth markers permanent with 4” numbers	
8. Markers at max. & min. depth, breakpoint & 2” depth intervals	
9. Minimum 2 entry / exits	
10. Depth markers no more than 25 feet	
11. Depth markers – feet and / or inches in 4” letters	
12. Wade pool 15ft from shallow /35ft from deepwater areas	
13. Wade pool fenced separately from pool / spa	
14. Wade pool with independent circulatory / sanitization system	

**SPA**

15. Chlorine 1.0 to 8.0 ppm	
16. Bromine 4.0 to 10.0 ppm	
17. pH 7.0 to 7.8	
18. Cyanuric acid outdoor spa (100 ppm or less)	
19. Water clarity sufficient / no algae	
20. Water temp 104F or less / spa thermometer available	
21. Emergency shutoff switch not <5’ & not >10’ from spa	
22. Manually operated 15min timer switch available to users	
23. Depth markers ft and / or inches in 4” letters	

**ELECTRICAL**

24. Pump(s) grounded and bonded	
25. Service electrical disconnect with in sight of pool / spa equipment	
26. ORP meter in use / mV reading 600 -900 mV	

**SUCTION OUTLETS IN POOLS & SPAS**

27. Suction outlet cover(s)/grate(s) intact and in place	
28. Dual Suction outlets or single suction outlet with SVRS	

**CIRCULATION EQUIPMENT & MECHANICAL**

29. Pump and filter functioning	
30. Circulation equipment has pump vacuum or vacuum pressure gauge	
31. Filter inlet and outlet gauge, and flowmeter in place	
32. Exposed piping labeled with function & directions of flow	
33. Written operation & maintenance instructions provided	
34. Pool/spa heater has TDLR operation certificate	
35. No user access to heater controls	
36. Skimmer basket not used to dispense chemicals	
37. Skimmer covers in place	

**FILL WATER / DRINKING WATER / OPERATION**

38. 1x1 stripe on leading edge of benches & water lounges	
39. 1x1 strip on leading edge of underwater / swimout steps	
40. Fill water public water supply	
41. Water distribution system protected against backflow	

**BATH HOUSE & SANITARY FACILITIES**

42. Facilities clean and sanitary	
43. Mirror shatter resistant & soap dispenser metal or plastic	
44. Toilet paper and holder provided	
45. Single use towels or hand dryer provided	
46. Covered waste receptacles	
47. Floor slip resistant & sloped to floor drains	
48. Private gender specific facilities	

**GLASS CONTAINERS & FOOD**

49. Glass containers not in pool / spa yard	
50. Trash containers provided	

**AQUATIC PLAY FEATURES**

51. Wave pool has rope and float line restricting access to caisson wall	
52. Wave and Surf pools have 2 emergency shut off switches	

**NO DIVING MARKERS & TRANSITION LINE**

53. Min. 2 - 4” “NO DIVING” letters & symbol no more than 25’ apart	
54. 4”x 4” line on bottom at transition from shallow to deep	

**SIGNS**

55. Sign(s) visible to pool/spa user in all areas of pool/spa yard	
56. No Diving in 4" letters & symbol where applicable	
57. Warning – No Lifeguard on Duty as applicable - 4" letters	
58. In Case of Emergency Dial 911 – 4" letters	
59. Emergency "Phone" location sign visible in pool/spa yard	
60. Pool / spa maximum user load – 2" letters	
61. Emergency spa shut off – 2" letters	
62. Location of emergency phone or device when applicable – 2" letters	
<b>63. Pets in pool / spa prohibited – 2" letters</b>	
<b>64. Persons less than 14yrs not in pool without adult supervision – 2" letters</b>	
<b>65. Extended breath holding activities prohibited – 2" letters</b>	
<b>66. Glass items not allowed – 2" letters</b>	
<b>67. Changing diapers within 6' of pool prohibited – 2" letters</b>	
<b>68. Do not swim if ill with diarrhea in past 2 weeks – 2" letters</b>	
<b>69. Do not use spa if water temp. is over 104°F – 1" letters</b>	

**SPECIFIC SAFETY FEATURES**

70. Emergency phone within 200' and not answered by onsite office	
71. Emergency phone operable / charged	
72. Min. 12' non-conductive reaching pole within 20' of pool	
73. USCG ring buoy with throw rope within 20' of pool	
74. Lifeguards provided at pools as required	

**CLASS A & B AND ALL RESIDENTIAL YOUTH CAMPS**

75. Minimum fence height 6 feet	
76. Fence designed to be difficult to climb	
77. Opening in or under fence do not allow passage of 4" sphere	
78. Gate(s) / door(s) continuously & directly supervised or locked	
79. Service gate not in use, closed and locked	

**CLASS C, D & DAY CAMPS POOLS / SPAS NOT SUBJECT TO HSC757**

80. Minimum fence height 48" (4 feet)	
81. Gate(s)/door(s) self-closing and self-latching	
82. Openings do not allow passage 4" sphere	
83. Hardware on gates and doors at least 3-1/2ft above ground	
84. Gate not propped open	
85. Gate or door open outward away from pool / spa	
86. Service gate not in use closed and locked	
87. No building in pool/spa yard with exits out of pools/spa yard	

**ALL POOLS & SPAS SUBJECT TO HSC757**

88. Minimum height 48"	
89. Gate(s)/door(s) not propped open	
90. Service gate not in use, closed and locked	
91. Latch either on outside of gate & min 60" above the ground	
92. Latch inside gate 3" below the top of gate or door; and	
93. No openings exceeding 1/2 "within 18" of the latch	
94. Latch min 42" above ground & opens with key, card or comb	
95. Horizontals at least 36" apart with gaps less than 4"	
<b>96. After 1/1/94 horizontals ≥ 45" apart/gaps ≤ 4", or</b>	
<b>97. After 1/1/94 horizontals &lt; 45" gaps no greater than 1-3/4"</b>	
<b>98. After 1/1/94, No chain link fencing</b>	
<b>99. After 1/1/94, gate(s) / door(s) open outward</b>	
<b>100. After 1/1/94 No fence cutouts w/ gaps greater than 1-3/4"</b>	

*Signs that are in bold letters are not required unless signs are replaced after 01/01/2021 or the facility constructed on or after 01/01/2021. A complete list of all new sign requirements can be found at: <https://dshs.texas.gov/poolspa/guidance.aspx>.*

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Inspected by(signature):	Owner/Operator(signature):
Printed Name:	Printed Name: