



ENVIRONMENTAL HEALTH DIVISION

550 Landa Street
 New Braunfels, TX 78130
 Office - 830-221-4070; Fax – 830-608-2117
 Email: healthdept@nbtexas.org
www.NBTexas.org

**Public
 Swimming Pools and
 Spas**

Facility Name:		Date:	
County: COMAL / GUADALUPE		Phone:	
Facility Address:		City: NEW BRAUNFELS	
Mailing Address:		State/Zip:	
Permit Number:		<input type="checkbox"/> Pre-10/01/99 <input type="checkbox"/> Post-10/01/99	<input type="checkbox"/> Class A <input type="checkbox"/> Class B <input type="checkbox"/> Class C <input type="checkbox"/> Spa <input type="checkbox"/> Wade <input type="checkbox"/> w/PIWF
Inspection Type: <input type="checkbox"/> Routine <input type="checkbox"/> Complaint <input type="checkbox"/> Re-Inspection <input type="checkbox"/> Pre-Licensing <input type="checkbox"/> Other (specify):			

“X” indicates an alleged deficiency "COS" indicates corrected on site *Items in italics apply to post-10/01/99 pools and spas*

Swimming Pool	
1. Chlorine (1-8 ppm) Bromine (2.5-12 ppm)	36. Filter on pre-10/01/99 pool or spa functioning.
2. pH (7.0 - 7.8)	37. Pump vacuum/inlet/outlet gauges & flowmeter.
3. Cyanuric acid (100 ppm or less)	38. Heater over 200,000 BTU with TDLR certificate.
4. Deck & sidewall depth markers permanent with 4" numbers.	39. Exposed piping labeled to identify function & flow direction.
5. Markers at max. & min. depth, breakpoint & 2' depth intervals.	<i>40. Filter on post-10/01/99 pool or spa functioning.</i>
6. Minimum 2 entry exits.	<i>41. Strainer on pump.</i>
<i>7. Depth markers no more than 25 feet apart.</i>	Operation, Water Quality & Structural Design
<i>8. Depth markers – feet and / or inches 4" letters.</i>	42. DPD test kit.
Wade Pool	43. Automatic chlorinator installed and operational.
9. Chlorine (1-8 ppm) Bromine (2.5-12 ppm)	44. No algae.
10. pH (7.0 - 7.8)	45. Water clear – deepest point of pool / spa clearly visible.
11. Cyanuric acid (100 ppm or less)	46. Skimmer basket not used to dispense sanitizer.
12. Deck & sidewall depth markers permanent with 4" numbers.	47. Skimmer cover securely in place.
<i>13. Depth markers no more than 25 feet apart.</i>	<i>48. Pool / spa bottom and sides light color or white.</i>
<i>14. Depth markers – feet and / or inches in 4" letters.</i>	<i>49. 1 x 1 stripe on leading edge of benches & water lounges.</i>
<i>15. Wade pool 15 feet from shallow / 35 feet from deepwater areas.</i>	<i>50. 1 x 1 stripe on leading edge of underwater / swimout steps.</i>
<i>16. Wade pool fenced separately from pool / spa.</i>	Electrical
<i>17. Wade pool w/ independent circulatory / sanitization system.</i>	51. Lights in pool / spa equipped with GFCI(s).
Spa	52. Pool / spa yard & bathhouse electrical outlet(s) with GFCI(s).
18. Chlorine (2-8 ppm) Bromine (4.5-12 ppm)	53. Pump(s) grounded and bonded.
19. pH (7.0 - 7.8)	54. Service electrical disconnect w/in sight of pool / spa equipment.
20. Cyanuric acid (100 ppm or less)	Fill Water/Drinking Water
21. Temperature 104°F or less / Spa thermometer available to users.	55. Fill water potable supply.
22. Emergency shutoff in sight & minimum 5 ft. away.	56. Water distribution system protected against backflow.
23. Maximum user load limit sign provided.	57. Over-the-rim fill spout with secure soft pliable end.
24. "Do Not Use Spa if Temp. Is Above 104°F" – 1 in. letters.	58. Drinking water available.
25. "Children Should Not Use Spa w/o Adult Supervision" – 2".	Specific Safety Features – No Diving Markers & Transition Line
26. Minimum 2 permanent deck depth markers with 4" numbers.	59. Min. 2-4" "NO DIVING" letters & symbol no more than 25' apart.
<i>27. 15 min timer-switch minimum 5 feet away from spa.</i>	60. 4" x 4" line on bottom at transition from shallow to deep.
<i>28. Depth marker feet and / or inches in 4" letters.</i>	Specific Safety Features - Signage
Suction Outlets (Main Drains)	61. Sign(s) visible to pool / spa user in all areas of pool / spa yard.
29. Suction outlet cover(s) / grate(s) intact and in place.	62. NO DIVING - 4" letters and symbol.
30. Single suction outlet-SVRD or AVS installed.	63. WARNING-NO LIFEGUARD ON DUTY - 4" letters.
31. No check valve(s) down-stream of pump.	64. Children Should Not Use Pool w/o Adult Supervision -2" letters.
32. Equalizer outlet(s) with approved cover or sealed.	65. IN CASE OF EMERGENCY– DIAL 911 - 1" letters.
33. Suction outlet VGBA / ASME/ANSI compliant.	66. Phone location sign visible in pool / spa yard.
<i>34. Dual main drains.</i>	Specific Safety Features – Safety Equipment
Mechanical	67. Min 12' non-conductive pole within 20' of pool.
35. Pump functioning.	68. USCG ring buoy w/ throw rope within 20' of pool.
	69. Emergency phone location sign on pool / spa gate (if required).

70. Emergency phone w/in 200' & not answered by onsite office.	84. Lifeguard chair(s) at least 4 feet above deck to view diving area.
71. Emergency phone functioning.	85. Boards / platforms 1/2 - 1 M with single guard & handrails.
Class A & B Pools / Spas	86. Boards / platforms over 1 M with 2 / dual guard & handrails.
72. Operator license(s) current and available.	87. Diving board(s) properly labeled.
73. Water tested every 2 hours pool / spa is in use (see log).	Bathroom & Sanitary Facilities
74. Rope and float line at shallow to deep transition.	88. Facilities clean and sanitary.
75. Dressing / sanitary facilities provided.	89. Mirror shatter resistant & soap dispenser metal or plastic.
Lifeguard / Second Responder	90. Toilet paper & holder provided.
76. Lifeguard(s) provided as required (Class A & B/slide/diving board).	91. Single use towels or hand dryer provided.
77. Current certification(s) available.	92. Covered waste receptacles.
78. Second responder on duty.	93. Floor slip resistant & sloped to floor drains.
79. Sufficient number of rescue tubes provided.	94. Private gender specific facilities.
80. Backboard with 3 tie-down straps & head immobilizer.	Glass Containers and Food
81. First aid kit with anti-disease transmission capabilities.	95. Glass containers in pool / spa yard.
82. Sufficient in-service training provided (60 minutes / week).	96. Trash containers provided.
Diving Facilities	Gas Chlorination
83. Distance between multiple boards minimum 10 feet.	97. Meets minimum standards.

**Pool enclosures not subject to HSC 757 include: hotels, youth camps, RV parks, Class B, child care, schools, etc.
Pool enclosures subject to HSC 757 are at multi-unit dwelling facilities: apartments, HOA's, condominiums, townhomes, etc.**

Class C, Class D, and Day Camp Pools & Spas Not Subject to HSC 757	ALL POOLS AND SPAS SUBJECT TO HSC 757
98. Minimum 48-inch height.	112. Minimum 48-inch height.
99. Gate(s) / door(s) self-closing and self-latching.	113. Gate(s) / door(s) self-closing and self-latching.
100. Gate(s) / door(s) not propped open.	114. Gate(s) / door(s) not propped open.
101. Openings in or under fence do not allow passage of 4" sphere.	115. Openings in chain link fabric less than 2-1/4".
102. No structures within 36" allowing fence to be scaled.	116. Latch must either be outside & minimum 60" above the ground; or
103. Opening hardware min. 42" above ground.	117. Latch must be inside only & 3" below top of gate / door; and
104. Post 10/01/99 no chain link fence after 9/1/2004.	118. No openings exceeding 1/2" w/in 18" of latch.
105. Post-10/01/99 gate(s) / door(s) open outward.	119. Latch min. 42" above ground & opens w/ key, card, or comb.
106. Post-10/01/99 No building door opening directly into pool yard or spa yard that opens outside enclosure.	120. Horizontals at least 36" apart w/gaps less than 4".
CLASS A & B AND ALL RESIDENTIAL YOUTH CAMPS	121. After 1/01/1994 horizontals less than 45" apart and no gaps greater than 1-3/4"; or
107. Minimum fence height 6 feet.	122. After 01/01/1994 horizontals min. 45" apart/gaps less than 4".
108. Fence designed to be difficult to climb.	123. No chain link after 01/01/94.
109. Openings in or under fence do not allow passage of 4" sphere.	124. Windows in wall(s) permanently closed after 01/01/1994.
110. Building door does not open outside pool/spa enclosure.	125. After 1/01/1994 gate(s) / door(s) open outward.
111. Gate(s) / Door(s) continuously & directly supervised or locked.	126. No fence cutouts w/gaps greater than 1-3/4" after 01/01/94.

Comments: _____

Inspected by (signature):	Representative (signature):
Printed Name:	Printed Name:
Date:	Date: